

Volume of Cooler or Freezer, Ft <sup>3</sup> (meter <sup>3</sup> )		Quantity	Notes
25,000	(708)	1	<p>(A) Minimum temperature of use is -20°F</p> <p>(B) For room sizes between two listings, use the higher quantity</p> <p>(C) The table above should be used as a general guideline only. Kason does not guarantee these numbers, as many factors beyond those assumed can affect the amount of ventilation required in a refrigerated space. Some of these factors include, but are not limited to:</p> <ul style="list-style-type: none"> <li>• The number of doors in the enclosure</li> <li>• Air-tightness of the enclosure</li> <li>• Refrigeration load (how quickly the temperature drops)</li> <li>• Strength of panel construction, etc.</li> </ul>
50,000	(1,415)	2	
75,000	(2,123)	3	
100,000	(2,830)	4	
200,000	(5,660)	8	